Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EN047

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JIM DARBY			Phone #: (715)635-3115
Mailing Address: HCR 58			
City: SPOONER	State: WI	Zip Code: 54871	
County: Burnett	Co. Permit #:	Notification #:	Completed: 04-24-1992

Well Constructor (Business Name): BEECROFT, ROGER	Lic. #: 182	Facility ID # (Public Wells):	
Address: RT 1 BOX 91BB SHELL LAKE WI 54871-9801		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.5	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of SCOTT

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #	
Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code
or Govt Lot # 006	Section 24	Township 40 N	Range 14 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
5	Surface	58

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		P		HARDPAN	Surface	15
		G	C	GRAVEL @ CLAY	15	47
		S		SAND	47	58

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	NEW BLACK STEEL 15 LB A53B SAWHILL WELDED	Surface	54.5
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	STAINLESS STEEL	54	58

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE GRANULARS	Surface	0	

9. Static Water Level
22 ft. below ground surface

10. Pump Test
Pumping level 35 ft. below surface
Pumping at 20 GP for 1 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RB		05-04-1992
Drill Rig Operator	Lic or Reg #	Date Signed
RB		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		10

Comment:

Created On: 06-09-1992 Updated On: 06-09-1992 Review Status: