

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EN103		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner ALAN ANDRUS					Phone # (715)489-3483		1. Well Location				Fire # (if avail.)												
Mailing Address CRANBERRY RD					Town of HUTCHINS					Street Address or Road Name and Number													
City BIRNAMWOOD			State WI		Zip Code 54414																		
County Shawano		Co. Permit #		Notification #		Completed 05-13-1992		Subdivision Name			Lot #		Block #										
Well Constructor (Business Name) KOEPPPEL, PHILIP J				Lic. # 667		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)			Method Code												
Address W6824 RED RIVER RD ANTIGO WI 54409-9051				Well Plan Approval #		Approval Date (mm-dd-yyyy)		°N °W		SW NW Section Township Range or Govt Lot # 20 29 N 12 E													
								12. Well Type New Well															
Hicap Permanent Well #		Common Well #		Specific Capacity 1.5		Reason for replaced or reconstructed well ? ADDITIONAL WATER FOR FARM																	
3. Well serves 1 # of BARN				Hicap Well ? No		Construction Type Drilled																	
Private, potable				Hicap Property ? No																			
Heat Exchange ____ # of drillholes				Hicap Potable ?																			
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method												8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)							
5		Surface		62		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)		C S SANDY CLAY Y SAND @ GRAVEL Q C S SANDY CLAY CAVING X U MUDDY SAND @ CLAY G S SANDY GRAVEL		Surface 4 4 25 25 40 40 58 58 62													
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		39 ft. below ground surface				24 in. above grade									
5		BLACK STEEL 14.62#/FT. .258" A53B WELDED SAWHILL				Surface		59		10. Pump Test				Developed ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 52 ft. below surface				Disinfected ? Yes									
5		STAINLESS JOHNSON #30				59		62		Pumping at 20 GP for 2 Hrs.				Capped ? Yes									
5		STAINLESS JOHNSON #30				59		62		Pumping Method ?				12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?									
7. Grout or Other Sealing Material Method										13. Constructor / Supervisory Driller										Lic #		Date Signed	
Method										PK										05-13-1992			
										Drill Rig Operator										Lic or Reg #		Date Signed	
										Method										Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		300	Silo/Storage Tube		80
Manure Hopper or Reception Tank - Liquid Tight		270	Animal Yard - Include Hutches		55
Building Overhang		3	Barn Gutter		180
Sewer - Building Sanitary		300	Septic or Holding, or POWTS Tank		300

Comment:

Created On: 06-03-1992

Updated On: 06-03-1992

Review Status: