Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EN318

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JOHN BYL			Phone #: (715)294-2732
Mailing Address: 303 SOUTH AVE APT 4			
City: OSCEOLA	State: WI	Zip Code: 54020	
County: Polk	Co. Permit #:	Notification #:	Completed: 05-22-1992

Well Constructor (Business Name): BEECROFT, DANIEL J	Lic. #: 602	Facility ID # (Public Wells):	
Address: RT 2 BOX 139B FREDERIC WI 54837-9599		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 2	

1. Well Location

Town of EUREKA EAST PART

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

SW NW or Govt Lot #:	Section: 30	Township: 35 N	Range: 18 W

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: WATER

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	133

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	35
		C	S	SANDY CLAY	35	52
		S		SAND	52	100
		C	S	SANDY CLAY	100	106
		S		SAND	106	133

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	SAWHILL A53 BLK. PLN. END. BX. WLD.	Surface	128.5
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	JOHNSON #10 S.S.	128.5	133

9. Static Water Level

105 ft. below ground surface

10. Pump Test

Pumping level 110 ft. below surface

Pumping at 10 GP for 1 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DB		05-22-1992
Drill Rig Operator	Lic or Reg #	Date Signed
DB		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 06-24-1992 Updated On: 06-24-1992 Review Status: