Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EN319

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BILL MIKA			Phone #: (715)269-5491
Mailing Address: 168 147TH ST			
City: DEER PARK	State: WI	Zip Code: 54807	
County: Polk	Co. Permit #:	Notification #:	Completed: 05-20-1992

Well Constructor (Business Name): BEECROFT, DANIEL J	Lic. #: 602	Facility ID # (Public Wells):	
Address: RT 2 BOX 139B FREDERIC WI 54837-9599		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.7	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of ALDEN

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code

NW SW or Govt Lot #	Section	Township	Range
	27	32 N	17 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
WATER

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	58

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	SAND	Surface	8
Y	SAND @ GRAVEL	8	35
S	SAND	35	58

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	SAWHILL A53 BLK. PLN. END. BX. WLD.	Surface	54.58
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	JOHNSON #10 S.S.	54.58	58

7. Grout or Other Sealing Material
Method

9. Static Water Level
25 ft. below ground surface

10. Pump Test
Pumping level 40 ft. below surface
Pumping at 10 GP for 1 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DB		05-20-1992
Drill Rig Operator	Lic or Reg #	Date Signed
DB		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60

Type	Qualifier	Distance
Building Overhang		20
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 06-24-1992 Updated On: 06-24-1992 Review Status: