Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EN321

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROBERT RANDLE	Phone #: (612)726-2239
Mailing Address: 4149 CHOWEN AVE S	
City: MINNEAPOLIS	State: MN Zip Code: 55410
County: Polk	Co. Permit #:
Notification #	Completed: 05-28-1992
Well Constructor (Business Name): BEECROFT, DANIEL J	Lic. #: 602
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: RT 2 BOX 139B FREDERIC WI 54837-9599	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 2	

1. Well Location

Town of LAKETOWN				Fire # (if avail.): 2648
Street Address or Road Name and Number: 231ST ST				
Subdivision Name			Lot #	Block #
Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code
NE SE or Govt Lot #	Section: 19	Township: 36 N	Range: 18 W	

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?: WATER
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	20
4	20	60

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 8in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	S	SANDY CLAY	Surface	35
		G	S	SANDY GRAVEL	35	60

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	SAWHILL A53 BLK. PLN. END. BX. WLD.	Surface	56.17
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	JOHNSON #18 S.S.	56.17	60

7. Grout or Other Sealing Material

Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	20	

9. Static Water Level
25 ft. below ground surface

10. Pump Test
Pumping level 35 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DB		05-28-1992
Drill Rig Operator	Lic or Reg #	Date Signed
DB		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		2	Septic or Holding, or POWTS Tank		30

Comment:

Created On: 06-24-1992 Updated On: 01-16-2019 Review Status: