

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EN321		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner ROBERT RANDLE				Phone # (612)726-2239		1. Well Location				Fire # (if avail.)	
Mailing Address 4149 CHOWEN AVE S						Town of LAKETOWN				2648	
City MINNEAPOLIS				State MN Zip Code 55410		Street Address or Road Name and Number 231ST ST					
County Polk		Co. Permit #		Notification #		Completed 05-28-1992		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) BEECROFT, DANIEL J				Lic. # 602		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W		Method Code	
Address RT 2 BOX 139B FREDERIC WI 54837-9599				Well Plan Approval #		NE SE Section Township Range or Govt Lot # 19 36 N 18 W		2. Well Type New Well			
Hicap Permanent Well #				Common Well #		Specific Capacity 2		of previous unique well # constructed in			
3. Well serves 1 # of Private,potable				Hicap Well ? No		Hicap Property ? No		Reason for replaced or reconstructed well ?			
Heat Exchange ___ # of drillholes				Hicap Potable ? No		Construction Type Drilled		WATER			
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock		
8		Surface		20		No Rotary - Mud Circulation			No		
4		20		60		No Rotary - Air			No		
						No Rotary - Air & Foam			No		
						No Drill-Through Casing Hammer					
						No Reverse Rotary					
						Yes Cable-tool Bit 8in. dia...			No		
						No Dual Rotary			No		
						No Temp. Outer Casing ___ in. dia					
						No Removed? ___ depth ft. (If NO explain on back side)					
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
C S		SANDY CLAY				Surface		35			
G S		SANDY GRAVEL				35		60			
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)			
4		SAWHILL A53 BLK. PLN. END. BX. WLD.				Surface		56.17			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
4		JOHNSON #18 S.S.				56.17		60			
7. Grout or Other Sealing Material											
Method GRAVITY											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement					
CLAY SLURRY		Surface		20							
9. Static Water Level											
25 ft. below ground surface											
10. Pump Test											
Pumping level 35 ft. below surface											
Pumping at 20 GP M for 1 Hrs.											
Pumping Method ?											
11. Well Is											
14 in. above grade											
Developed ? Yes											
Disinfected ? Yes											
Capped ? Yes											
12. Notified Owner of need to fill & seal ? No											
Filled & Sealed Well(s) as needed? No											
13. Constructor / Supervisory Driller											
Lic #		Date Signed									
DB		05-28-1992									
Drill Rig Operator		Lic or Reg #		Date Signed							
DB											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		2	Septic or Holding, or POWTS Tank		30

Comment:

Created On: 06-24-1992

Updated On: 01-16-2019

Review Status: