

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EN338		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner MARSHLAND FARMS						Phone # (414)255-4033		1. Well Location				Fire # (if avail.)			
Mailing Address PO BOX 425						Town of BUFFALO									
City GERMANTOWN						State WI		Zip Code 53022							
County Marquette		Co. Permit #		Notification #		Completed 05-29-1992		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) PHILLIPS, JAMES R				Lic. # 541		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code			
Address 592 CTY A GRAND MARSH WI 53936				Well Plan Approval #		SE SE Section Township Range or Govt Lot # 2 14 N 10 E		2. Well Type New Well				of previous unique well # constructed in			
Hicap Permanent Well #		Common Well #		Specific Capacity		Reason for replaced or reconstructed well ? HAD NO WELL									
3. Well serves 1 # of Private, potable				Hicap Well ? No		Construction Type Drilled									
Heat Exchange ___ # of drillholes				Hicap Property ? No											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
2 Surface 35			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 1in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)												
1.25 35 39															
8. Geology															
Dia. (in.) From (ft.) To (ft.)			Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.) To (ft.)						
2 Surface 35			S			SAND			Surface 32						
1.25 35 39			Y			SAND GRAVEL			32 39						
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)		9. Static Water Level				11. Well Is			
2		SAWHILL NEW STEEL ASTM 589 3.75# R@D COUPLED				Surface 35		20 ft. below ground surface				16 in. above grade			
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)		10. Pump Test				Developed ? Yes			
1.25		STAINLESS SCREEN				35 39		Pumping level 20 ft. below surface				Disinfected ? Yes			
7. Grout or Other Sealing Material												Pumping at 12 GP for 2 Hrs.		Capped ? Yes	
Method												Pumping Method ?			
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? No															
WERE NONE															
13. Constructor / Supervisory Driller						Lic #		Date Signed							
JP								05-29-1992							
Drill Rig Operator						Lic or Reg #		Date Signed							

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 06-19-1992

Updated On: 06-19-1992

Review Status: