Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EN428

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BUD SUMMERFIELD			Phone #: (715)635-2900
Mailing Address: BOX 28			
City: TREGO	State: WI	Zip Code: 54888	
County: Washburn	Co. Permit #:	Notification #:	Completed: 05-12-1992

Well Constructor (Business Name): LINDSTROM, JAMES C	Lic. #: 101	Facility ID # (Public Wells):
Address: RT 2 BOX 2228 SPOONER WI 54801-9438		Well Plan Approval #: Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity:

1. Well Location

Town of TREGO

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

SW SW or Govt Lot #	Section: 35	Township: 39 N	Range: 12 W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	70

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Q	S		CAVING BROWN SAND	Surface	45
T		Y		BROWN SAND @ GRAVEL WATER BEARING	45	70

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	ASTM A53B T@C @ .237 WALL 2210 P.S.I. VALLEY STEEL	Surface	70
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
	OPEN BOTTOM		

9. Static Water Level

45 ft. below ground surface

10. Pump Test

Pumping level 45 ft. below surface

Pumping at 10 GP for 24 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JCL		05-14-1992
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60

Type	Qualifier	Distance
Building Overhang		10
Septic or Holding, or POWTS Tank		45

Comment:

Created On: 06-19-1992 Updated On: 06-19-1992 Review Status: