Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EN430

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RALPH EICHTON			Phone #: (612)560-7905
Mailing Address: 8032 ORCHARD AVE N			
City: BROOKLYN PARK	State: MN	Zip Code: 55443	
County: Burnett	Co. Permit #:	Notification #:	Completed: 05-26-1992

1. Well Location

Town of JACKSON

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
LINDSTROM, JAMES C	101	

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

or Govt Lot #	NE	NE	Section: 13	Township: 40 N	Range: 15 W

Well Plan Approval #

Address: RT 2 BOX 2228
SPOONER WI 54801-9438

Approval Date (mm-dd-yyyy)

2. Well Type New Well

of previous unique well # constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		1.2

Reason for replaced or reconstructed well ?

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	58

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		S		BROWN CAVING SAND	Surface	20
T		C		BROWN CLAY	20	35
	W	Y		WATER BEARING SAND @ GRAVEL	35	58

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	ASTM A53B T@C .237 WALL 2210 PSI	Surface	54
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	VALLEY STEEL STAINLESS #10	54	58

9. Static Water Level

30 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 12 GP for 24 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JCL		06-02-1992
Drill Rig Operator	Lic or Reg #	Date Signed
CPL		05-28-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 06-19-1992 Updated On: 06-19-1992 Review Status: