

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EN430		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner RALPH EICHTON Phone # (612)560-7905						1. Well Location				Fire # (if avail.)				
Mailing Address 8032 ORCHARD AVE N						Town of JACKSON				Street Address or Road Name and Number				
City BROOKLYN PARK				State MN		Zip Code 55443								
County Burnett		Co. Permit #		Notification #		Completed 05-26-1992		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) LINDSTROM, JAMES C				Lic. # 101		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code		
Address RT 2 BOX 2228 SPOONER WI 54801-9438				Well Plan Approval #		NE NE Section Township Range or Govt Lot # 13 40 N 15 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled						
Approval Date (mm-dd-yyyy)				Specific Capacity 1.2		Hicap Permanent Well #						Common Well #		
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?										
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.) 4		From (ft.) Surface		To (ft.) 58		Upper Enlarged Drillhole Lower Open Bedrock Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)		To (ft.)						
T S			BROWN CAVING SAND			Surface		20						
T C			BROWN CLAY			20		35						
W Y			WATER BEARING SAND @ GRAVEL			35		58						
6. Casing, Liner, Screen														
Dia. (in.) 4		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) Surface		To (ft.) 54						
Dia. (in.) 4		Screen type, material & slot size				From (ft.) 54		To (ft.) 58						
7. Grout or Other Sealing Material Method														
9. Static Water Level 30 ft. below ground surface														
10. Pump Test Pumping level 40 ft. below surface Pumping at 12 GP for 24 Hrs. Pumping Method ?														
11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes														
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes														
13. Constructor / Supervisory Driller						Lic #		Date Signed						
JCL						Lic or Reg #		Date Signed						
Drill Rig Operator						Date Signed		05-28-1992						

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 06-19-1992

Updated On: 06-19-1992

Review Status: