Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EN443

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JOHN SANTA		Phone #: (612)436-5628
Mailing Address: 16252 2ND ST N		
City: LAKELAND	State: MN	Zip Code: 55043

County	Co. Permit #	Notification #	Completed
Washburn			05-27-1992

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
LINDSTROM, JAMES C	101	

Address: RT 2 BOX 2228
SPOONER WI 54801-9438

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.6

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of SARONA

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD) °N °W

Method Code

NW	NE	Section	Township	Range
or Govt Lot #		8	37 N	12 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	50

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		S		BROWN CAVING SAND	Surface	20
T		M		BROWN SILT	20	30
	W	Y		WATER BEARING SAND @ GRAVEL	30	50

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	ASTM A53B T@C .237 WALL 2110 PSI VALLEY STEEL	Surface	46
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS #10	46	50

7. Grout or Other Sealing Material
Method

9. Static Water Level
20 ft. below ground surface

10. Pump Test
Pumping level 36 ft. below surface
Pumping at 10 GP for 24 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JCL		02-02-1992
Drill Rig Operator	Lic or Reg #	Date Signed
CPL		05-28-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		10	Septic or Holding, or POWTS Tank		65

Comment:

Created On: 06-19-1992 Updated On: 06-19-1992 Review Status: