

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EO201		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner CHARLES RADAKE Phone # (414)495-2328						1. Well Location				Fire # (if avail.)							
Mailing Address W2061 THAYER RD						Town of SUGAR CREEK				Street Address or Road Name and Number N7294 MC CABE RD							
City JEFFERSON				State WI		Zip Code 53549											
County Walworth		Co. Permit #		Notification #		Completed 04-24-1992		Subdivision Name			Lot #		Block #				
Well Constructor (Business Name) VOGEL, ALBIN				Lic. # 634		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.7553 °N -88.6605 °W				Method Code GCD013			
Address RT 1 JEFFERSON WI 53549-9801				Well Plan Approval #				NW NW		Section 6		Township 3 N		Range 16 E			
				Approval Date (mm-dd-yyyy)				or Govt Lot #		6		3 N		16 E			
Hicap Permanent Well #			Common Well #			Specific Capacity 1.9			2. Well Type New Well								
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes			Hicap Well ? No Hicap Property ? No Hicap Potable ?			of previous unique well # constructed in											
						Reason for replaced or reconstructed well ? NEW HOME											
4. Potential Contamination Sources - ON REVERSE SIDE						Construction Type Drilled											
						5. Drillhole Dimensions and Construction Method						8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		21		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		C CLAY		CLAY		Surface		26			
6		21		305								Z MIXED CLAY @ GRAVEL		26		70	
6		21		305								C CLAY		70		240	
6		21		305								L LIME ROCK		240		305	
6		21		305								L LIME ROCK		240		305	
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		117 ft. below ground surface							
6		NEW STEEL PLAIN END WITH WELDED JOINTS WEIGHING 18.97 LBS PER FOOT ASTM A-53 US MADE BY SAWHILL				Surface		240		14 in. above grade							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test							
6		NEW STEEL PLAIN END WITH WELDED JOINTS WEIGHING 18.97 LBS PER FOOT ASTM A-53 US MADE BY SAWHILL				Surface		240		Developed ? Yes							
6		NEW STEEL PLAIN END WITH WELDED JOINTS WEIGHING 18.97 LBS PER FOOT ASTM A-53 US MADE BY SAWHILL				Surface		240		Disinfected ? Yes							
6		NEW STEEL PLAIN END WITH WELDED JOINTS WEIGHING 18.97 LBS PER FOOT ASTM A-53 US MADE BY SAWHILL				Surface		240		Capped ? Yes							
7. Grout or Other Sealing Material						Pumping level 125 ft. below surface				Filled & Sealed Well(s) as needed? No							
Method						Pumping at 15 GP for 3 Hrs.											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		Pumping Method ?									
CLAY SLURRY		Surface		21		21		12. Notified Owner of need to fill & seal ?									
CLAY SLURRY						NONE IN AREA				13. Constructor / Supervisory Driller							
CLAY SLURRY						NONE IN AREA											
CLAY SLURRY						NONE IN AREA											
CLAY SLURRY						NONE IN AREA											
CLAY SLURRY						NONE IN AREA				Lic #				Date Signed			
CLAY SLURRY						NONE IN AREA				AV				04-30-1992			
CLAY SLURRY						NONE IN AREA				Drill Rig Operator				Lic or Reg #		Date Signed	
CLAY SLURRY						NONE IN AREA				AV/M				04-30-1992			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		106	Building Overhang		30
Building Drain - Sanitary		38	Sewer - Building Sanitary		44
			Septic or Holding, or POWTS Tank		91

Comment:

Created On: 06-03-1992

Updated On: 09-12-2019

Review Status: