Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EO202

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HOWARD L WIENHOLTZ			Phone #: (608)221-8485
Mailing Address: 3286 CTH BB #4			
City: MADISON	State: WI	Zip Code: 53704	
County: Dane	Co. Permit #: W05267	Notification #	Completed: 04-29-1992

Well Constructor (Business Name): VOGEL, ALBIN	Lic. #: 634	Facility ID # (Public Wells)	
Address: RT 1 JEFFERSON WI 53549-9801		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 2.1	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of OREGON

Fire # (if avail.)

Street Address or Road Name and Number: 5400 MARIE RD

Subdivision Name: CSM 5133		Lot #: 00001	Block #
Latitude / Longitude in Decimal Degree (DD): 42.8981 °N -89.429 °W			Method Code: GCD013
NE NE or Govt Lot #	Section: 21	Township: 5 N	Range: 9 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	21
6	21	208

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 10in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	50
L	LIME ROCK	50	208

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL PLAIN END WITH WELDED JOINTS WEIGHING18.97 LBS. PER FOOT ASTM A-53 US MADE BY SAWHILL	Surface	50
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	21	

9. Static Water Level
90 ft. below ground surface

10. Pump Test
Pumping level 97 ft. below surface
Pumping at 15 GP for 3 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
NONE IN AREA

13. Constructor / Supervisory Driller	Lic #	Date Signed
AV		04-30-1992
Drill Rig Operator	Lic or Reg #	Date Signed
AV/M		04-30-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		72	Sewer - Building Sanitary		90

Comment:

Created On: 06-03-1992 Updated On: 12-11-2019 Review Status: