

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EO202		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner HOWARD L WIENHOLTZ						Phone # (608)221-8485		1. Well Location				Fire # (if avail.)											
Mailing Address 3286 CTH BB #4						Town of OREGON						Street Address or Road Name and Number 5400 MARIE RD											
City MADISON				State WI		Zip Code 53704																	
County Dane		Co. Permit # W05267		Notification #		Completed 04-29-1992		Subdivision Name CSM 5133				Lot # 00001		Block #									
Well Constructor (Business Name) VOGEL, ALBIN				Lic. # 634		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.8981 °N -89.429 °W				Method Code GCD013									
Address RT 1 JEFFERSON WI 53549-9801				Well Plan Approval #		NE NE Section Township Range or Govt Lot # 21 5 N 9 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW HOME															
				Approval Date (mm-dd-yyyy)																			
Hicap Permanent Well #		Common Well #		Specific Capacity 2.1		Construction Type Drilled																	
3. Well serves 1 # of Private, potable				Hicap Well ? No																			
Heat Exchange ___ # of drillholes				Hicap Property ? No																			
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method												8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)							
10		Surface		21		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		C CLAY		L LIME ROCK		Surface		50									
6		21		208								50		208									
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		90 ft. below ground surface				14 in. above grade									
6		NEW STEEL PLAIN END WITH WELDED JOINTS WEIGHING 18.97 LBS. PER FOOT ASTM A-53 US MADE BY SAWHILL				Surface		50		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 97 ft. below surface Pumping at 15 GP for 3 Hrs. Pumping Method ?													
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?											
Method												Filled & Sealed Well(s) as needed? No NONE IN AREA											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement															
CLAY SLURRY				Surface		21				13. Constructor / Supervisory Driller				Lic #		Date Signed							
								AV						04-30-1992									
								Drill Rig Operator						Lic or Reg #		Date Signed							
								AV/M								04-30-1992							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		72	Sewer - Building Sanitary		90

Comment:

Created On: 06-03-1992

Updated On: 12-11-2019

Review Status: