Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EO602

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BRAIN ROOT			Phone #: (715)575-4827
Mailing Address: RT 1 BOX 355C			
City: HOLCOMBE	State: WI	Zip Code: 54745	
County: Chippewa	Co. Permit #: W06125	Notification #	Completed: 04-17-1992

Well Constructor (Business Name): WILLMARTH, LARRY L	Lic. #: 241	Facility ID # (Public Wells)
Address: RT 3 BOX 132 HOLCOMBE WI 54745-9739		Well Plan Approval #
		Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 3.3

1. Well Location

Town of LAKE HOLCOMBE

Fire # (if avail.)

Street Address or Road Name and Number: CLARK RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

SE NW or Govt Lot #	Section: 20	Township: 32 N	Range: 6 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: WATER FOR NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	33

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T S	SAND/CAVING/BROWN/MED TO HARD	Surface	33

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6.625	O.D.X.280WX 18.97#/FT ASTMA53 88A GRD B P.E. BEV.	Surface	30
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	X4' JOHNSON STAINLESS	29	33

9. Static Water Level

14 ft. below ground surface

10. Pump Test

Pumping level 17 ft. below surface

Pumping at 10 GP for 24 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
LW		04-20-1992
Drill Rig Operator	Lic or Reg #	Date Signed
LW		04-20-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Landfill		1320

Comment:

Created On: 06-01-1992 Updated On: 06-01-1992 Review Status: