

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EO602		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner BRAIN ROOT					Phone # (715)575-4827		1. Well Location				Fire # (if avail.)			
Mailing Address RT 1 BOX 355C					Town of LAKE HOLCOMBE									
City HOLCOMBE					State WI		Zip Code 54745							
County Chippewa		Co. Permit # W06125		Notification #		Completed 04-17-1992		Street Address or Road Name and Number CLARK RD						
Well Constructor (Business Name) WILLMARTH, LARRY L					Lic. # 241		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code		
Address RT 3 BOX 132 HOLCOMBE WI 54745-9739					Well Plan Approval #		SE NW		Section 20		Township 32 N		Range 6 W	
Hicap Permanent Well #					Common Well #		Specific Capacity 3.3		2. Well Type New Well					
3. Well serves 1 # of					Hicap Well ? No		of previous unique well # constructed in							
Private, potable					Hicap Property ? No		Reason for replaced or reconstructed well ? WATER FOR NEW HOME							
Heat Exchange ____ # of drillholes					Hicap Potable ?		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock					
6		Surface		33		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)								
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6.625		O.D.X.280WX 18.97#/FT ASTMA53 88A GRD B P.E. BEV.				Surface		30						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
4		X4' JOHNSON STAINLESS				29		33						
7. Grout or Other Sealing Material Method														
8. Geology														
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...					From (ft.)		To (ft.)				
T S			SAND/CAVING/BROWN/MED TO HARD					Surface		33				
9. Static Water Level 14 ft. below ground surface										11. Well Is 12 in. above grade				
10. Pump Test Pumping level 17 ft. below surface Pumping at 10 GP for 24 Hrs. Pumping Method ?										Developed ? Yes Disinfected ? Yes Capped ? Yes				
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?														
13. Constructor / Supervisory Driller								Lic #		Date Signed				
LW										04-20-1992				
Drill Rig Operator								Lic or Reg #		Date Signed				
LW										04-20-1992				

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Type	Qualifier	Distance
Landfill		1320

Comment:

Created On: 06-01-1992

Updated On: 06-01-1992

Review Status: