

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EO686		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner PAT BEAN						Phone # () 687-2297		1. Well Location				Fire # (if avail.)	
Mailing Address C1725 FAIRVIEW RD						Town of CLEVELAND							
City STRATFORD						State WI		Zip Code 54484					
County Marathon		Co. Permit #		Notification #		Completed 05-18-1992		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) HAUPT, SYLVESTER R				Lic. # 489		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code	
Address AUBURNDALE WI 54412				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NW SW Section Township Range or Govt Lot # 16 27 N 4 E					
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW RESIDENCE							
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock							
8.625		Surface		40		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)							
6		40		102									
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
		I				TOPSOIL		Surface		1			
		C				CLAY		1		13			
D	Q					ROTTON GRANITE		13		32			
		Q				GRANITE		32		102			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		ASTM A53 GRADE B 280 WALL WELDED YKK HAISHINGSTEEL				Surface		40					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method PRESSURE													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement							
NEAT CEMENT		Surface		40		8							
9. Static Water Level													
8 ft. below ground surface													
10. Pump Test													
Pumping level 80 ft. below surface Pumping at 1 GP for 2.5 Hrs. Pumping Method ?													
11. Well Is													
18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller						Lic #		Date Signed					
SYH								05-18-1992					
Drill Rig Operator						Lic or Reg #		Date Signed					
SCH													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		20	Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 06-09-1992

Updated On: 06-09-1992

Review Status: