Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EO738

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROLAND MCCULLOCK	Phone #: (414)592-8177
Mailing Address: 512 W2638B CHANCERY	
City: WAUKESHA	State: WI — Zip Code: 53188
County: Waushara	Co. Permit #: — Notification #: — Completed: 05-13-1992
Well Constructor (Business Name): WELCH, ETHAN A	Lic. #: 647 — Facility ID # (Public Wells):
Address: RT 2 FREMONT WI 54940-9802	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 3.8

1. Well Location

Town of MARION

Fire # (if avail.):

Street Address or Road Name and Number: CYPRESS RD

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NW SE — Section: 19 — Township: 18 N — Range: 11 E

or Govt Lot #:

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

COTTAGE

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	73

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	24
		S	G	SAND @ STONES	24	31
		Y	C	SAND GRAVEL @ CLAY	31	61
		Y		SAND @ GRAVEL	61	73

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW T@C VALLEY STEEL 11 LB PER FT A.S.T.M.A. 53BP.S.I. 2210	Surface	69
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	15 SLOT STAINLESS	69	73

9. Static Water Level

33 ft. below ground surface

10. Pump Test

Pumping level 37 ft. below surface

Pumping at 15 GP for 16 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

STILL USING

13. Constructor / Supervisory Driller	Lic #	Date Signed
EW		05-13-1992
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		57	Privy		54
Building Drain - Sanitary		26	Sewer - Building Sanitary		27
Building Overhang		18	Septic or Holding, or POWTS Tank		38

Comment:

Created On: 06-19-1992 Updated On: 06-19-1992 Review Status: