

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EO738		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner ROLAND MCCULLOCK						Phone # (414)592-8177		1. Well Location				Fire # (if avail.)			
Mailing Address 512 W2638B CHANCERY						Town of MARION						Street Address or Road Name and Number CYPRESS RD			
City WAUKESHA				State WI		Zip Code 53188									
County Waushara		Co. Permit #		Notification #		Completed 05-13-1992		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) WELCH, ETHAN A				Lic. # 647		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code	
Address RT 2 FREMONT WI 54940-9802				Well Plan Approval #				°N		°W		NW SE Section Township Range or Govt Lot # 19 18 N 11 E			
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #				Common Well #		Specific Capacity 3.8				2. Well Type New Well					
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?				Reason for replaced or reconstructed well ? COTTAGE							
								Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
4		Surface		73		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
S				SAND				Surface		24					
S G				SAND @ STONES				24		31					
Y C				SAND GRAVEL @ CLAY				31		61					
Y				SAND @ GRAVEL				61		73					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
4		NEW T@C VALLEY STEEL 11 LB PER FT A.S.T.M.A. 53BP.S.I. 2210				Surface		69							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
3		15 SLOT STAINLESS				69		73							
7. Grout or Other Sealing Material Method															
9. Static Water Level 33 ft. below ground surface															
10. Pump Test Pumping level 37 ft. below surface Pumping at 15 GP for 16 Hrs. Pumping Method ?															
11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No STILL USING															
13. Constructor / Supervisory Driller															
Lic #															
Date Signed															
EW															
05-13-1992															
Drill Rig Operator															
Lic or Reg #															
Date Signed															

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		57	Privy		54
Building Drain - Sanitary		26	Sewer - Building Sanitary		27
Building Overhang		18	Septic or Holding, or POWTS Tank		38

Comment:

Created On: 06-19-1992

Updated On: 06-19-1992

Review Status: