

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EO739		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner DENNIS NEUBAUER						Phone # (414)867-2576		1. Well Location				Fire # (if avail.)							
Mailing Address R32B HWY 10 RT 1						Town of ROYALTON						R32B							
City WEYAUWEGA						State WI		Zip Code 54983				Street Address or Road Name and Number HWY 10							
County Waupaca		Co. Permit #		Notification #		Completed 05-18-1992		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) WELCH, ETHAN A				Lic. # 647		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address RT 2 FREMONT WI 54940-9802				Well Plan Approval # Approval Date (mm-dd-yyyy)		SE NW		Section 33		Township 22 N		Range 13 E							
						or Govt Lot #													
Hicap Permanent Well #				Common Well #		Specific Capacity 1.7		2. Well Type New Well				of previous unique well # constructed in							
Reason for replaced or reconstructed well ? HOME																			
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock						Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)						
10 Surface 20			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 10in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? ___depth ft. (If NO explain on back side)						X G		SAND CLAY @ STONES		Surface 4						
6 20 113									C S		CLAY @ SAND		4 98						
									S		SAND		98 113						
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)		3 ft. above ground surface				16 in. above grade							
6		T@C VALLEY STEEL 19.45 LB PER FT A.S.T.M.A. 53.BP.S.I. 1780				Surface 109		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)		Pumping level 20 ft. below surface				Disinfected ? Yes							
5		10 SLOT STAINLESS				109 113		Pumping at 40 GP for 3 Hrs.				Capped ? Yes							
								Pumping Method ?											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?					
Method GRAVITY																			
Kind of Sealing Material				From (ft.) To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?											
CLAY SLURRY				Surface 20															
13. Constructor / Supervisory Driller														Lic #		Date Signed			
EW																06-01-1992			
Drill Rig Operator														Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		43	Shoreline/Pool		27
Building Overhang		31	Sewer - Building Sanitary		60
Foundation Drain to Clearwater		31	Septic or Holding, or POWTS Tank		70

Comment:

Created On: 06-19-1992

Updated On: 06-19-1992

Review Status: