

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EO741		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner BERNARD PRICE						Phone # () 642-5457		1. Well Location				Fire # (if avail.)	
Mailing Address 3010 OLEARY LN						Village of HANCOCK							
City EAST TROY						State WI		Zip Code 53120					
County Waushara		Co. Permit #		Notification #		Completed 06-01-1992		Subdivision Name				Lot # Block #	
Well Constructor (Business Name)				Lic. # 647		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code	
WELCH, ETHAN A								°N °W					
Address RT 2 FREMONT WI 54940-9802				Well Plan Approval #		SE SW Section Township Range or Govt Lot # 11 19 N 8 E							
				Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #		Common Well #		Specific Capacity 18									
3. Well serves 1 # of Private, potable				Hicap Well ? No									
Heat Exchange ___ # of drillholes				Hicap Property ? No									
				Hicap Potable ?									
								Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock					
8		Surface		20									
4		20		63		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 8in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)							
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
4		T@C VALLEY STEEL 11 LBS PER FT A.S.T.M.A. 53BP.S.I. 2210 V.S.P. COLLANG				Surface		59					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
3		15 SALOT STAINLESS				59		63					
7. Grout or Other Sealing Material													
Method GRAVITY													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
CLAY SLURRY				Surface		20							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)							
C G		CLAY @ STONES		Surface		6							
C S		CLAY SAND @ GRAVEL @ BOULDER		6		46							
Y		SAND @ GRAVEL		46		63							
9. Static Water Level						36 ft. below ground surface		11. Well Is					
								14 in. above grade					
10. Pump Test						Pumping level 37 ft. below surface		Developed ? Yes					
						Pumping at 18 GP for 16 Hrs.		Disinfected ? Yes					
						Pumping Method ?		Capped ? Yes					
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller						Lic #		Date Signed					
EW								06-02-1992					
Drill Rig Operator						Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		29	Collector Sewer - San or Storm		73
Building Overhang		19	Sewer - Building Sanitary		42

Comment:

Created On: 06-19-1992

Updated On: 06-19-1992

Review Status: