Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EO818

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROBERT ROLLYSON			Phone #: (414)539-3233
Mailing Address: 9640 W LAYTON AVE			
City: GREENFIELD	State: WI	Zip Code: 53228	
County: Waupaca	Co. Permit #:	Notification #:	Completed: 05-26-1992

Well Constructor (Business Name): JOHNSON, MICHAEL	Lic. #: 545	Facility ID # (Public Wells):	
Address: RT 1 BOX 14A OGDENSBURG WI 54962-9704		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 3	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of IOLA

Fire # (if avail.):

Street Address or Road Name and Number: TRESSNESS RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

NW SE or Govt Lot #	Section	Township	Range
	23	24 N	11 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW MOBILE HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	20
4	20	48

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 8in. dia...
- Dual Rotary .....
- Yes Temp. Outer Casing 8in. dia
- Yes Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y		SAND @ GRAVEL	Surface	28
G		C	G	GREY CLAY GRAVEL	28	36
		Y		W-SAND @ GRAVEL	36	48

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	4" NEW ASTM 589 SAWHILL T@C R@D 11 LB FOOT	Surface	44
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	10 SLOT STAINLESS STEEL K PACKER JOHNSON	44	48

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	20	

9. Static Water Level
15 ft. below ground surface

10. Pump Test
Pumping level 20 ft. below surface
Pumping at 15 GP for 24 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
MJ		06-01-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MJ		06-01-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		85

Type	Qualifier	Distance
Building Overhang		20
Septic or Holding, or POWTS Tank		70

Comment:

Created On: 06-19-1992 Updated On: 06-19-1992 Review Status: