

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EO818		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner ROBERT ROLLYSON Phone # (414)539-3233						1. Well Location				Fire # (if avail.)									
Mailing Address 9640 W LAYTON AVE Address						Town of IOLA				Street Address or Road Name and Number TRESSNESS RD									
City GREENFIELD			State WI		Zip Code 53228														
County Waupaca		Co. Permit #		Notification #		Completed 05-26-1992		Subdivision Name			Lot #		Block #						
Well Constructor (Business Name) JOHNSON, MICHAEL				Lic. # 545		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code							
Address RT 1 BOX 14A OGDENSBURG WI 54962-9704				Well Plan Approval #		Approval Date (mm-dd-yyyy)		°N °W		NW SE Section Township Range or Govt Lot # 23 24 N 11 E									
Hicap Permanent Well #		Common Well #		Specific Capacity 3		2. Well Type New Well of previous unique well # constructed in													
Reason for replaced or reconstructed well ? NEW MOBILE HOME		Construction Type Drilled																	
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes												Hicap Well ? No Hicap Property ? No Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8		Surface		20		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 8in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 8in. dia <u>Yes</u> Removed? ___depth ft. (If NO explain on back side)		G Y G C G Y		SAND @ GRAVEL		Surface		28					
4		20		48						GREY CLAY GRAVEL		28		36					
4		20		48						W-SAND @ GRAVEL		36		48					
4		20		48						48		48		48					
4		20		48						48		48		48					
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		15 ft. below ground surface				14 in. above grade					
4		4" NEW ASTM 589 SAWHILL T@C R@D 11 LB FOOT				Surface		44		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 20 ft. below surface Pumping at 15 GP for 24 Hrs. Pumping Method ?				12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?					
4		10 SLOT STAINLESS STEEL K PACKER JOHNSON				44		48											
7. Grout or Other Sealing Material												13. Constructor / Supervisory Driller MJ Drill Rig Operator MJ				Lic # Lic or Reg # Date Signed 06-01-1992 Date Signed 06-01-1992			
Method																			
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement													
CLAY SLURRY		Surface		20		20		20											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		85	Building Overhang		20
			Septic or Holding, or POWTS Tank		70

Comment:

Created On: 06-19-1992

Updated On: 06-19-1992

Review Status: