Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EO839

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: THOMAS MEYER			Phone #: (414)464-2956
Mailing Address: 3609 83RD ST			
City: MILWAUKEE	State: WI	Zip Code: 53222	
County: Waushara	Co. Permit #:	Notification #:	Completed: 05-01-1992

Well Constructor (Business Name): JENKS, LARRY L	Lic. #: 203	Facility ID # (Public Wells):	
Address: RT 2 BOX 1422 WILD ROSE WI 54984-9327		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 2.5	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of SPRINGWATER

Fire # (if avail.):

Street Address or Road Name and Number: APACHE RD

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code:

NW NE or Govt Lot #	Section: 23	Township: 20 N	Range: 11 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	186

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Q	S		CAVING SAND	Surface	50
		C		CLAY	50	120
	N	S		FINE SAND	120	178
	N	Y		WATER BEARING SAND @ GRAVEL	178	186

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	VSPCO ASTM A53B T@C 11#/FT. HYDRO TEST 2210	Surface	182
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	X4' 10 SLOT STAINLESS SCREEN	182	186

7. Grout or Other Sealing Material
Method

9. Static Water Level
30 ft. below ground surface

10. Pump Test
Pumping level 38 ft. below surface
Pumping at 20 GP for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
LJ		05-12-1992
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55

Type	Qualifier	Distance
Building Overhang		9
Septic or Holding, or POWTS Tank		45

Comment:

Created On: 06-03-1992 Updated On: 06-03-1992 Review Status: