

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EO839		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner THOMAS MEYER						Phone # (414)464-2956		1. Well Location				Fire # (if avail.)									
Mailing Address 3609 83RD ST						Town of SPRINGWATER						Street Address or Road Name and Number APACHE RD									
City MILWAUKEE				State WI		Zip Code 53222															
County Waushara		Co. Permit #		Notification #		Completed 05-01-1992		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) JENKS, LARRY L				Lic. # 203		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code							
Address RT 2 BOX 1422 WILD ROSE WI 54984-9327				Well Plan Approval #				°N °W		NW NE Section Township Range or Govt Lot # 23 20 N 11 E		2. Well Type New Well		of previous unique well # constructed in							
				Approval Date (mm-dd-yyyy)																	
Hicap Permanent Well #				Common Well #		Specific Capacity 2.5				Reason for replaced or reconstructed well ? NEW HOME											
3. Well serves 1 # of Private, potable						Hicap Well ? No		Construction Type Drilled													
Heat Exchange ___ # of drillholes						Hicap Property ? No								Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
4		Surface		186		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				Q S				CAVING SAND		Surface		50			
4		Surface		186						C				CLAY		50		120			
										N S				FINE SAND		120		178			
										N Y				WATER BEARING SAND @ GRAVEL		178		186			
										4				Surface		182		186			
										4				Surface		182		186			
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		30 ft. below ground surface				12 in. above grade							
4		VSPCO ASTM A53B T@C 11#/FT. HYDRO TEST 2210				Surface		182		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 38 ft. below surface				Disinfected ? Yes							
4		X4' 10 SLOT STAINLESS SCREEN				182		186		Pumping at 20 GP for 2 Hrs.				Capped ? Yes							
4		X4' 10 SLOT STAINLESS SCREEN				182		186		Pumping Method ?				12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?							
7. Grout or Other Sealing Material Method																					
13. Constructor / Supervisory Driller										Lic #		Date Signed									
										LJ		05-12-1992									
										Drill Rig Operator		Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Building Overhang		9
			Septic or Holding, or POWTS Tank		45

Comment:

Created On: 06-03-1992

Updated On: 06-03-1992

Review Status: