Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EO985

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JOSEPH WAGNER	Phone #: (414)414-2249
Mailing Address: 1282 9TH ST	
City: GREEN BAY	State: WI — Zip Code: 54304
County: Oconto	Co. Permit #:
Notification #	Completed: 04-30-1992

1. Well Location

Town of RIVERVIEW

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name | Lot # | Block #

Well Constructor (Business Name): JONES, NOBLE F	Lic. #: 640	Facility ID # (Public Wells)	Latitude / Longitude in Decimal Degree (DD): °N °W	Method Code
		Well Plan Approval #	NW NW or Govt Lot #	Section: 35 — Township: 32 N — Range: 16 E
Address: RT 2 10460 HWY A SURING WI 54174-9802		Approval Date (mm-dd-yyyy)		
Hicap Permanent Well #	Common Well #:	Specific Capacity: 0.2		

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

FOR TRAILER HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	77

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Q	X	G	SAND, CLAY, GRAVEL MIX-CAVING	Surface	35
		G	G	GRAVEL BOULDERS	35	77

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A-53 18.97# SAWHILL STEEL WELDED	Surface	65
5	ASTM A-53 SAWHILL STEEL	65	77
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MUD CIRC

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	20	

9. Static Water Level

50 ft. below ground surface

10. Pump Test

Pumping level 70 ft. below surface

Pumping at 3 GP for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
NJ		05-25-1992
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		85
Building Drain - Sanitary		75

Type	Qualifier	Distance
Building Overhang		6
Sewer - Building Sanitary		95
Septic or Holding, or POWTS Tank		75

Comment:

Created On: 06-09-1992 Updated On: 06-09-1992 Review Status: