Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EO986

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WALTER RAHY			Phone #: (715)674-3922
Mailing Address: RT 1			
City: LAONA	State: WI	Zip Code: 54541	
County: Forest	Co. Permit #:	Notification #:	Completed: 04-30-1992

1. Well Location

Town of NASHVILLE

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: | Lot #: | Block #:

Well Constructor (Business Name): JONES, NOBLE F	Lic. #: 640	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): 45.5314 °N -88.85695 °W	Method Code: GPS008
Address: RT 2 10460 HWY A SURING WI 54174-9802		Well Plan Approval #:	SW NW or Govt Lot #:	Section: 10	Township: 35 N	Range: 13 E
		Approval Date (mm-dd-yyyy):		

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?

FOR NEW HOME

Hicap Permanent Well #: | Common Well #: | Specific Capacity: 0.1

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	123

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Q	X	G	SAND CLAY STONE MIX-CAVING	Surface	35
		C	G	CLAY GRAVEL	35	75
	W	S		STICKY SAND	75	115
		G		GRAVEL	115	123

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A-53 18.97# SAWHILL STEEL-WELDED	Surface	120
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	STAINLESS STEEL-TELESCOPING	120	123

9. Static Water Level

5 ft. below ground surface

10. Pump Test

Pumping level 100 ft. below surface

Pumping at 5 GP for 0.5 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MUD CIRC.

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
NJ		05-25-1992
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		20	Shoreline/Pool		75
Building Overhang		10	Sewer - Building Sanitary		35
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 06-09-1992 Updated On: 08-19-2022 Review Status: