

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EP011		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner LORETTA M RULAND						Phone # (608)795-2614		1. Well Location				Fire # (if avail.)							
Mailing Address 6701 HWY 78						Town of N. OF MAZOMANIE													
City MAZOMANIE						State WI		Zip Code 53560											
County Dane		Co. Permit # W05395		Notification #		Completed 05-04-1992		Subdivision Name				Lot #							
								Block #											
Well Constructor (Business Name) HERBECK, ALBIN R				Lic. # 482		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.22247 °N -89.74781 °W									
						Well Plan Approval #				Method Code GPS008									
Address PO BOX 37 SEXTONVILLE WI 53584-0037						Approval Date (mm-dd-yyyy)				SW SE Section Township Range or Govt Lot # 26 9 N 6 E									
Hicap Permanent Well #				Common Well #		Specific Capacity				2. Well Type Replacement									
										of previous unique well # constructed in									
										Reason for replaced or reconstructed well ? NEEDED WATER									
3. Well serves 1 # of DWELLING				Hicap Well ? No						Construction Type Drilled									
Private, potable				Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock																
10 Surface 20																			
6 20 150																			
			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 10in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? ___depth ft. (If NO explain on back side)																
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		26 ft. below ground surface				12 in. above grade					
6		SCED 40 18:97PE. PITLESS ASTM A53 6 5/8 O.D. 250ERW SAWHILL U.S.A.				Surface		100		10. Pump Test				Developed ? Yes					
										Pumping level 26 ft. below surface				Disinfected ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 10 GP for 1 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?					
Method																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No									
BENTONITE SLURRY				Surface		100				OWNERS RESPONSIBILITY									
13. Constructor / Supervisory Driller								Lic #		Date Signed									
AH										05-22-1992									
Drill Rig Operator								Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Nonconforming Pit or Alcove	>	50
Building Drain - Sanitary	>	10	Sewer - Building Sanitary	>	8
Building Overhang	>	2	Septic or Holding, or POWTS Tank	>	25

Comment:

Created On: 06-09-1992

Updated On: 08-19-2022

Review Status: