

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EP046		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner BRAD RITTMER					Phone #		1. Well Location				Fire # (if avail.)								
Mailing Address PO BOX 466							Village of SILVER LAKE												
City SILVER LAKE					State WI		Zip Code 53170		Street Address or Road Name and Number 8930 FOX RIVER RD										
County Kenosha		Co. Permit #		Notification #		Completed 05-05-1992		Subdivision Name			Lot # Block #								
Well Constructor (Business Name) WILTON, THOMAS J				Lic. # 132		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 42.5455 °N -88.1808 °W			Method Code GCD013								
Address PO BOX 172 SALEM WI 53168-0172				Well Plan Approval # Approval Date (mm-dd-yyyy)		NE SW		Section 18		Township 1 N		Range 20 E							
						or Govt Lot #													
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
5		Surface		53		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 5in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				Q X G C S		SAND @ CLAY C. GRAY CLAY SAND		Surface 20 50		20 50			
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		12 ft. below ground surface				20 in. above grade					
5		BLK T@C ASTMA 53 1950 PSI VSP				Surface		50		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 12 ft. below surface Pumping at 20 GP for 4 Hrs. Pumping Method ?									
5		PVC				50		53											
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method MUD HOLE												Filled & Sealed Well(s) as needed?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed			
#8 BENTONITE @ DRILLING MUD				Surface		53				TW						05-06-1992			
										Drill Rig Operator				Lic or Reg #		Date Signed			
										JF						05-06-1992			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		15

Comment:

Created On: 06-01-1992

Updated On: 08-23-2019

Review Status: