Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EP051

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KEN SAVAGE			Phone #
Mailing Address: 31103 75TH ST			
City: SALEM	State: WI	Zip Code: 53168	
County: Kenosha	Co. Permit #	Notification #	Completed: 05-04-1992
Well Constructor (Business Name): WILTON, THOMAS J	Lic. #: 132	Facility ID # (Public Wells)	
Address: PO BOX 172 SALEM WI 53168-0172		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 10	

1. Well Location

Town of SALEM

Fire # (if avail.)

Street Address or Road Name and Number: 31103 75TH ST

Subdivision Name	Lot #	Block #
SHOREWOOD TER	00006	1

Latitude / Longitude in Decimal Degree (DD)	Method Code
42.5676 °N -88.1868 °W	GCD013

SW SW or Govt Lot #	Section	Township	Range
	7	1 N	20 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
5	Surface	57

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 5in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	SAND @ CLAY	Surface	25
C	CLAY	25	50
S	SAND	50	57

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	BLK T@C ASTMA 53 1950 PSI V.S.P.	Surface	54
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5	PVC	54	57

7. Grout or Other Sealing Material

Method: MUD HOLE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 BENTONITE @ DRILLING MUD	Surface	57	

9. Static Water Level

8 ft. below ground surface

10. Pump Test

Pumping level 10 ft. below surface

Pumping at 20 GP for 4 Hrs.

Pumping Method ?

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TW		05-06-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JF		05-06-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Sewer - Building Sanitary		50
Building Overhang		20	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 06-01-1992 Updated On: 08-23-2019 Review Status: