Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EP059

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KEN MISSLING			Phone #: (414)733-2572
Mailing Address: 2107 ALEXANDRA			
City: APPLETON	State: WI	Zip Code: 54911	
County: Price	Co. Permit #:	Notification #:	Completed: 06-01-1992

1. Well Location

Town of ELK

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: | Lot #: | Block #:

Well Constructor (Business Name): KARNOSH, DONALD	Lic. #: 660	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): °N °W
Address: W7244 S MINNOW LAKE PHILLIPS WI 54555		Well Plan Approval #:	Method Code:
		Approval Date (mm-dd-yyyy):	

SW SE or Govt Lot #	Section: 6	Township: 37 N	Range: 1 W

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?

POINT PLUGED UP

Construction Type: Drilled

Hicap Permanent Well #	Common Well #	Specific Capacity: 3.3

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	37

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y	G	SAND @ GRAVEL @ ROCKS	Surface	26
		S	U	MUDDY SAND	26	33
		Y		SAND @ GRAVEL	33	37

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL SAWHILL A-53 #18.97 LB. P.E. 1780	Surface	37
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

12 ft. below ground surface

10. Pump Test

Pumping level 15 ft. below surface

Pumping at 10 GP for 4 Hrs.

Pumping Method ?

11. Well Is

15 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DK		06-03-1992
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		85

Type	Qualifier	Distance
Building Overhang		10
Septic or Holding, or POWTS Tank		75

Comment:

Created On: 06-24-1992 Updated On: 06-24-1992 Review Status: