Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EP060

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JOHN KERR			Phone #: (715)532-6313
Mailing Address: W10180 THORNAPPLE RD			
City: LADYSMITH	State: WI	Zip Code: 54848	
County: Price	Co. Permit #:	Notification #:	Completed: 05-28-1992

1. Well Location
Town of FLAMBEAU
Fire # (if avail.):
Street Address or Road Name and Number:
Subdivision Name: | Lot #: | Block #:

Well Constructor (Business Name): KARNOSH, DONALD	Lic. #: 660	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): °N °W
		Well Plan Approval #:	Method Code:
Address: W7244 S MINNOW LAKE PHILLIPS WI 54555		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.4	

NW SW | Section: 19 | Township: 38 N | Range: 1 W
or Govt Lot #:

2. Well Type New Well
of previous unique well #: constructed in:
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	40.5

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		P	G	HARD PAN @ ROCKS	Surface	35
R		S		RED SAND	35	40.5

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18.97 A-53 SAWHILL P.E. 1780	Surface	38.5
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	STAINLESS 18 SLOT	38.5	40.5

9. Static Water Level
25 ft. below ground surface

10. Pump Test
Pumping level 32 ft. below surface
Pumping at 10 GP for 4 Hrs.
Pumping Method ?

11. Well Is
15 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PUDDLE CLAY	Surface	20	

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DK		06-03-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		12

Comment:

Created On: 06-19-1992 Updated On: 06-19-1992 Review Status: