

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EP238		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner FAITH HARVEY						Phone # (414)787-4080		1. Well Location				Fire # (if avail.)					
Mailing Address RT 2 BOX 662								Town of MARION									
City WAUTOMA						State WI		Zip Code 54982									
County Waushara		Co. Permit #		Notification #		Completed 04-10-1992		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) FARAGO, JOE				Lic. # 284		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.0578 °N -89.1907 °W				Method Code GCD013					
Address 606 W POPLAR ST PLAINFIELD WI 54966-9673				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SE SE Section Township Range or Govt Lot # 4 18 N 11 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled							
Hicap Permanent Well #		Common Well #		Specific Capacity 4.3													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
4		Surface		58		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 4in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				TOP SOIL		Surface		38			
								C		CLAY		38		50			
								A Y		COURSE SAND @ GRAVEL		50		58			
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		21 ft. below ground surface		13 in. above grade					
4		ASTM A53, USS STEEL, 10.79# PER FT. THREAD @COUPLE 4 1/2 OD 2.37 WALL TYPE TESTED 2210 PSI				Surface		54.5		10. Pump Test		Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 24 ft. below surface Pumping at 13 GP for 2 Hrs.		Disinfected ? Yes					
4		#12 JOHNSON SCREEN				54.5		58		Pumping Method ?		Capped ? Yes					
7. Grout or Other Sealing Material Method												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes					
13. Constructor / Supervisory Driller								Lic #		Date Signed							
JF										04-13-1992							
Drill Rig Operator								Lic or Reg #		Date Signed							
JF										04-13-1992							

4a. Potential Contamination Sources

Is the well located in floodplain ?

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		57	Building Overhang		7
			Septic or Holding, or POWTS Tank		48

Comment:

Created On: 06-19-1992

Updated On: 05-05-2020

Review Status: