

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EP256		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner MR @ MRS ALLAN MENTZEL						Phone # (414)622-4985		1. Well Location				Fire # (if avail.)			
Mailing Address RT 2 BOX 116						Town of ROSE						Street Address or Road Name and Number			
City WILD ROSE				State WI		Zip Code 54984		Subdivision Name				Lot #		Block #	
County Waushara		Co. Permit #		Notification #		Completed 12-09-1992									
Well Constructor (Business Name) FARAGO PLUMBING @ TRENCHING INC				Lic. # 126		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code			
Address 606 W POPLAR ST PLAINFIELD WI 54966-9620				Well Plan Approval #		SW SE		Section 23		Township 20 N		Range 10 E			
						or Govt Lot #									
Approval Date (mm-dd-yyyy)				Hicap Permanent Well #		Common Well #		Specific Capacity 0.5		2. Well Type New Well					
Hicap Property ? No				Hicap Potable ?		Reason for replaced or reconstructed well ?									
Heat Exchange ___ # of drillholes				Hicap Well ? No		Construction Type Drilled									
3. Well serves 1 # of Private, potable															
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) 6		From (ft.) Surface		To (ft.) 200		Upper Enlarged Drillhole				Lower Open Bedrock					
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
X G				SAND CLAY GRAVEL				Surface		21					
S				SAND				21		122					
N S				FINE SAND				122		181					
M S				MED SAND				181		200					
6. Casing, Liner, Screen															
Dia. (in.) 6		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) Surface		To (ft.) 196							
		ASTM AL.USS STEEL-A53 19.97# PER FT. WELDED TOGETHER 6.625" ODX280 WALL-TESTED 2800 PSI													
Dia. (in.) 6		Screen type, material & slot size				From (ft.) 196		To (ft.) 200							
		#12 JOHNSON WITH K PACKER													
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.) Surface		To (ft.) 0		# Sacks Cement							
POWDER BENTONITE ALONG CASING															
9. Static Water Level															
104 ft. below ground surface															
10. Pump Test															
Pumping level 126 ft. below surface															
Pumping at 12 GP M for 1 Hrs.															
Pumping Method ?															
11. Well Is															
24 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed?															
13. Constructor / Supervisory Driller															
JF														12-08-1992	
Drill Rig Operator														Lic or Reg #	
TF														12-07-1992	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		54	Building Overhang		14
			Septic or Holding, or POWTS Tank		42

Comment:

Created On: 01-11-1993

Updated On: 01-11-1993

Review Status: