Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EP257

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MIKE KELLER			Phone #
Mailing Address: 817 LINDBERG AVE			
City: STEVENS POINT	State: WI	Zip Code: 54481	
County: Portage	Co. Permit #	Notification #	Completed: 12-14-1992

Well Constructor (Business Name): FARAGO PLUMBING @ TRENCHING INC	Lic. #: 126	Facility ID # (Public Wells)
Address: 606 W POPLAR ST PLAINFIELD WI 54966-9620		Well Plan Approval #
		Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 6

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of ALMOND

Fire # (if avail.)

Street Address or Road Name and Number
JJ @ BRADY RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.31202 °N	-89.48689 °W			GPS008
NW or Govt Lot #	SW	Section: 007	Township: 7 21 N	Range: 9 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	80

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	N	CLAY SAND ROCK	Surface	30
		X	G	CLAY SAND GRAVEL	30	46
		Y		SAND @ GRAVEL	46	80

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A1.USS STEEL-A53 19.97# PER FT-WELDEDTOGETHER 6.625" ODX280 WALL TESTED 2800 PSI	Surface	76
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	#15 JOHNSON KPACKER	76	80

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
POWDER BENTONITE ALONG CASING	Surface	0	

9. Static Water Level
35 ft. below ground surface

10. Pump Test
Pumping level 37 ft. below surface
Pumping at 12 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
26 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
JF		12-15-1992
Drill Rig Operator	Lic or Reg #	Date Signed
TF		12-14-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 01-13-1993 Updated On: 08-19-2022 Review Status: