

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EP408		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner DENNIS RUBENZER						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 6811 S LOOMIS RD						Town of NORWAY															
City WIND LAKE						State WI		Zip Code 53185				Street Address or Road Name and Number 6811 S LOOMIS RD									
County Racine		Co. Permit #		Notification #		Completed 05-05-1992		Subdivision Name				Lot # Block #									
Well Constructor (Business Name) DANECKI, RICHARD L				Lic. # 124		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.8111 °N -88.1664 °W				Method Code GCD013							
Address PO BOX 94 NORTH PRAIRIE WI 53153-0094				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 17 4 N 20 E				2. Well Type New Well											
						Approval Date (mm-dd-yyyy)				of previous unique well # constructed in											
Hicap Permanent Well #		Common Well #		Specific Capacity 0.4		Reason for replaced or reconstructed well ? NEW HOME				Construction Type Drilled											
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		73		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						C CLAY		Surface		60					
												Y SAND @ GRAVEL		60		73					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		4 ft. below ground surface				16 in. above grade							
6		SAWHILL USA ASTM A53 6.625X.280 BEL20 HTY287171191				Surface		69		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 40 ft. below surface Pumping at 15 GP for 4 Hrs. Pumping Method ?											
5		STAINLESS STEEL SCREEN				69		73													
7. Grout or Other Sealing Material Method														12. Notified Owner of need to fill & seal ?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No NONE											
#8 MESH BENTONITE				Surface		69															
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														RD						05-05-1992	
														Drill Rig Operator				Lic or Reg #		Date Signed	
														SH						05-05-1992	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		11	Downspout/Yard Hydrant		13
Clearwater Sump		15	Foundation Drain to Clearwater		12
Collector Sewer - San or Storm		145	Sewer - Building Sanitary		60

Comment:

Created On: 06-09-1992

Updated On: 06-27-2019

Review Status: