Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EP413

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GARY BELMAN			Phone #
Mailing Address: 6843 S LOOMIS RD			
City: WIND LAKE	State: WI	Zip Code: 53185	
County: Racine	Co. Permit #	Notification #	Completed: 05-05-1992

Well Constructor (Business Name): DANECKI, RICHARD L	Lic. #: 124	Facility ID # (Public Wells)	
Address: PO BOX 94 NORTH PRAIRIE WI 53153-0094		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.6	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of NORWAY

Fire # (if avail.)

Street Address or Road Name and Number: 6843 S LOOMIS RD

Subdivision Name	Lot #: 00001	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
42.8117 °N	-88.1656 °W			GCD013
NW or Govt Lot #	NW	Section: 17	Township: 4 N	Range: 20 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	80

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	65
Y	SAND @ GRAVEL	65	80

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SAWHILL USA ASTM A53 6.625 X .280 BEL20 HTY287171191	Surface	76
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	STAINLESS STEEL SCREEN	76	80

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 MESH BENTONITE	Surface	76	

9. Static Water Level
7 ft. below ground surface

10. Pump Test
Pumping level 40 ft. below surface
Pumping at 20 GP for 4 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
RD		05-05-1992
Drill Rig Operator	Lic or Reg #	Date Signed
SH		05-05-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		11	Downspout/Yard Hydrant		13
Clearwater Sump		16	Foundation Drain to Clearwater		15
Collector Sewer - San or Storm		90	Sewer - Building Sanitary		44

Comment:

Created On: 06-19-1992 Updated On: 06-27-2019 Review Status: