

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EP772		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner TOM MOHR						Phone # (715)748-6415		1. Well Location				Fire # (if avail.)							
Mailing Address 880 MALIBU DR						Town of GOODRICH													
City MEDFORD						State WI		Zip Code 54451											
County Taylor		Co. Permit #		Notification #		Completed 05-17-1992		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) BRUNNER, WILLIAM D				Lic. # 515		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address 303 S 8TH MEDFORD WI 54451-1904				Well Plan Approval #		SW NE Section Township Range or Govt Lot # 28 31 N 3 E													
Hicap Permanent Well #				Common Well #		Specific Capacity 0.1		2. Well Type New Well				of previous unique well # constructed in							
Reason for replaced or reconstructed well ? NEW CONST.																			
3. Well serves 1 # of Private, potable						Hicap Well ? No													
Heat Exchange ___ # of drillholes						Hicap Property ? No													
						Hicap Potable ?		Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		20								P		HARDPAN		Surface		65	
6		20		96		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						S U		MUDDY SAND		65		80	
												U C		BLUE CLAY		80		86	
												Q		GRANITE		86		96	
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8 ft. below ground surface				26 in. above grade					
6		NEW BLK STL T@C A53B 19.45# V.S.P. 1780 PSI				Surface		86		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 80 ft. below surface				Disinfected ? Yes					
										Pumping at 6 GP for 3 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method												Filled & Sealed Well(s) as needed?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement				13. Constructor / Supervisory Driller				Lic #		Date Signed	
DRILL CUTTINGS				Surface		20						WDB						05-18-1992	
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		27	Sewer - Building Sanitary		60
			Septic or Holding, or POWTS Tank		65

Comment:

Created On: 06-09-1992

Updated On: 06-09-1992

Review Status: