Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EQ263

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PEGGY REINECK	Phone #
Mailing Address: HWY 57	
City: LUXEMBURG	State: WI Zip Code: 54217
County: Door	Co. Permit #	Notification #	Completed: 12-23-1991
Well Constructor (Business Name): EUCLIDE WELL DRILLING	Lic. #: 5860	Facility ID # (Public Wells)
Address: 2596 STONE RD STURGEON BAY WI 54235-9255	Well Plan Approval #	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.1

1. Well Location

Town of UNION

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

SW or Govt Lot #	SW	Section: 28	Township: 26 N	Range: 23 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	75
6	75	130

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Z	CLAY @ GRAVEL	Surface	75
H	SHALE	75	130

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL P.E. WT. 18.97 A-53 NEWPORT	Surface	75
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level 90 ft. below surface

Pumping at 10 GP for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PRESSURE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
MUD	Surface	35	
CEMENT	35	75	6

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
ME		03-16-1992
Drill Rig Operator	Lic or Reg #	Date Signed
WD		03-31-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 04-27-1992 Updated On: 04-27-1992 Review Status: