Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EQ264

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BUZ DAVIS			Phone #: (414)743-9440
Mailing Address: 6780 HWY 42-57			
City: STURGEON BAY	State: WI	Zip Code: 54235	
County: Door	Co. Permit #	Notification #	Completed: 12-13-1991

Well Constructor (Business Name): EUCLIDE WELL DRILLING	Lic. #: 5860	Facility ID # (Public Wells)	
Address: 2596 STONE RD STURGEON BAY WI 54235-9255		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.1	

3. Well serves 2 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of NASEWAUPEE

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD) °N °W

Method Code

SE NW or Govt Lot #	Section: 14	Township: 27 N	Range: 25 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
8	20	170
6	170	265

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Z	CLAY @ GRAVEL	Surface	20
L	LIMEROCK	20	265

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BALCK STEEL P.E. WT. 18.97 A-53 NEWPORT	Surface	170
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
60 ft. below ground surface

10. Pump Test
Pumping level 140 ft. below surface
Pumping at 10 GP for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method PRESSURE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
MUD	Surface	6	
CEMENT	6	170	38

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
OWNERS REQUEST

13. Constructor / Supervisory Driller	Lic #	Date Signed
ME		03-16-1992
Drill Rig Operator	Lic or Reg #	Date Signed
WD		03-31-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Septic or Holding, or POWTS Tank		60

Comment:

Created On: 04-27-1992 Updated On: 04-27-1992 Review Status: