

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EQ277		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner RODNEY TOLLEFSON						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address RT 1 BOX 62A						Town of FRANKLIN						Street Address or Road Name and Number							
City MELROSE				State WI		Zip Code 54642													
County Jackson		Co. Permit #		Notification #		Completed 05-01-1992		Subdivision Name			Lot #		Block #						
Well Constructor (Business Name) MAURER, GENE H				Lic. # 296		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code								
Address RT 4 BOX 272 BLACK RIVER FALLS WI 54615-9804				Well Plan Approval #		SW SE Section Township Range or Govt Lot # 15 20 N 6 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW HOME											
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #		Common Well #		Specific Capacity 1.8		Construction Type Drilled													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
10		Surface		30		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 10in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? ___depth ft. (If NO explain on back side)		T S CAVING BROWN SAND Surface 3 G S CAVING GRAY SAND 3 6 G N GRAY SAND ROCK 6 17 T N BROWN SANDROCK 17 25 G N GRAY SAND ROCK 25 77 I N WHITE SAND ROCK 77 100		72 ft. below ground surface		12 in. above grade		Developed ? Yes Disinfected ? Yes Capped ? Yes					
6		30		100															
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		10. Pump Test									
6		BLACK STEEL 1897 WELD ASTM-A53 SAWHILL TUBULAR USA				Surface		31		Pumping level 78 ft. below surface Pumping at 11 GP for 3 Hrs. Pumping Method ?									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?									
7. Grout or Other Sealing Material												13. Constructor / Supervisory Driller							
Method TREMIE PIPE GRAVITY																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
NEAT CEMENT				Surface		30		12											
GM Drill Rig Operator MM												Lic #		Date Signed					
												05-19-1992							
												Lic or Reg #		Date Signed					
												05-19-1992							

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 06-09-1992

Updated On: 06-09-1992

Review Status: