Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EQ278

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RAY GILBERTSON			Phone #: (715)284-5528
Mailing Address: RT 2			
City: BLACK RIVER FALLS	State: WI	Zip Code: 54615	
County: Jackson	Co. Permit #:	Notification #:	Completed: 05-15-1992

Well Constructor (Business Name): MAURER, GENE H	Lic. #: 296	Facility ID # (Public Wells):	
Address: RT 4 BOX 272 BLACK RIVER FALLS WI 54615-9804		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.2	

1. Well Location

Town of IRVING

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

NW SE or Govt Lot #:	Section: 12	Township: 20 N	Range: 5 W

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: OLD WELL TO BE USED FOR L

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	100

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K		I		CAVING BLACK DIRT	Surface	3
G		Q		CAVING BROWN CLAY	3	9
T		S		CAVING BROWN SAND	9	26
G		S		CAVING GRAY SAND	26	46
G		N		GRAY SAND ROCK	46	85
I		N		WHITE SAND ROCK	85	100

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL 1897 WELD ASTM-A53 SAWHILL TUBULAR USA	Surface	48
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

67 ft. below ground surface

10. Pump Test

Pumping level 76 ft. below surface

Pumping at 11 GP for 3 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
GM		05-20-1992
Drill Rig Operator	Lic or Reg #	Date Signed
MM		05-20-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		138
Building Overhang		33

Type	Qualifier	Distance
Sewer - Building Sanitary		100
Septic or Holding, or POWTS Tank		120

Comment:

Created On: 06-09-1992 Updated On: 06-09-1992 Review Status: