

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EQ278		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner RAY GILBERTSON						Phone # (715)284-5528		1. Well Location				Fire # (if avail.)									
Mailing Address RT 2						Town of IRVING						Street Address or Road Name and Number									
City BLACK RIVER FALLS				State WI		Zip Code 54615															
County Jackson		Co. Permit #		Notification #		Completed 05-15-1992		Subdivision Name			Lot #		Block #								
Well Constructor (Business Name) MAURER, GENE H				Lic. # 296		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code									
Address RT 4 BOX 272 BLACK RIVER FALLS WI 54615-9804				Well Plan Approval #		Approval Date (mm-dd-yyyy)		°N °W		NW SE Section Township Range or Govt Lot # 12 20 N 5 W		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? OLD WELL TO BE USED FOR L									
								Hicap Permanent Well #						Common Well #		Specific Capacity 1.2					
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.) 6		From (ft.) Surface		To (ft.) 100		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						K I		CAVING BLACK DIRT		Surface		3									
						G Q		CAVING BROWN CLAY		3		9									
						T S		CAVING BROWN SAND		9		26									
						G S		CAVING GRAY SAND		26		46									
						G N		GRAY SAND ROCK		46		85									
						I N		WHITE SAND ROCK		85		100									
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.) 6		Material, Weight, Specification BLACK STEEL 1897 WELD ASTM-A53 SAWHILL TUBULAR USA				From (ft.) Surface		To (ft.) 48		67 ft. below ground surface				12 in. above grade							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test Pumping level 76 ft. below surface Pumping at 11 GP for 3 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes							
7. Grout or Other Sealing Material Method														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?							
13. Constructor / Supervisory Driller GM Drill Rig Operator MM										Lic #		Date Signed									
										05-20-1992		05-20-1992									
										Lic or Reg #		Date Signed									
										05-20-1992		05-20-1992									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		138	Sewer - Building Sanitary		100
Building Overhang		33	Septic or Holding, or POWTS Tank		120

Comment:

Created On: 06-09-1992

Updated On: 06-09-1992

Review Status: