Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EQ279

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JOHN J SAPAULA			Phone #: (608)486-2341
Mailing Address: BOX 305			
City: BANGOR	State: WI	Zip Code: 54614	
County: Jackson	Co. Permit #:	Notification #:	Completed: 05-09-1992

1. Well Location

Town of NORTH BEND

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: | Lot #: | Block #:

Well Constructor (Business Name): MAURER, GENE H	Lic. #: 296	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): °N °W
		Well Plan Approval #:	Method Code:
Address: RT 4 BOX 272 BLACK RIVER FALLS WI 54615-9804		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.1	

SE	NW	Section: 10	Township: 19 N
or Govt Lot #			Range: 6 W

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	30
6	30	230

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 10in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
G		S		CAVING GRAY SAND	Surface	5
G		N		GRAY SAND ROCK	5	9
T		N		BROWN SAND ROCK	9	104
G		N		GRAY SAND ROCK	104	207
I		N		WHITE SANDROCK	207	230

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL 1897 WELD ASTM-A53 SAW HILL TUBULARU.S.A.	Surface	31
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

200 ft. below ground surface

10. Pump Test

Pumping level 208 ft. below surface

Pumping at 9 GP for 4 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PIPE GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	30	13

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
GM		05-20-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MM		05-20-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		8	Privy		57

Comment:

Created On: 06-19-1992 Updated On: 06-19-1992 Review Status: