Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EQ279

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner	JOHN J SAPAULA
Phone #	(608)486-2341
Mailing Address	BOX 305
City	BANGOR
State	WI
Zip Code	54614
County	Jackson
Co. Permit #	
Notification #	
Completed	05-09-1992
Well Constructor (Business Name)	MAURER, GENE H
Lic. #	296
Facility ID # (Public Wells)	
Well Plan Approval #	
Address	RT 4 BOX 272 BLACK RIVER FALLS WI 54615-9804
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	1.1

1. Well Location

Town of NORTH BEND	Fire # (if avail.)
Street Address or Road Name and Number	
Subdivision Name	Lot # / Block #
Latitude / Longitude in Decimal Degree (DD)	°N °W
Method Code	

SE NW or Govt Lot #	Section	Township	Range
	10	19 N	6 W

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
NEW HOME
Construction Type Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	30
6	30	230

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 10in. dia...
- Dual Rotary .....
- Yes Temp. Outer Casing 10in. dia
- Yes Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
G		S		CAVING GRAY SAND	Surface	5
G		N		GRAY SAND ROCK	5	9
T		N		BROWN SAND ROCK	9	104
G		N		GRAY SAND ROCK	104	207
I		N		WHITE SANDROCK	207	230

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL 1897 WELD ASTM-A53 SAW HILL TUBULARU.S.A.	Surface	31
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
200 ft. below ground surface

10. Pump Test
Pumping level 208 ft. below surface
Pumping at 9 GP for 4 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method TREMIE PIPE GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	30	13

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
GM		05-20-1992
Drill Rig Operator	Lic or Reg #	Date Signed
MM		05-20-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		8	Privy		57

Comment:

Created On: 06-19-1992 Updated On: 06-19-1992 Review Status: