Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EQ280

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CURT CHRISTOPHERSON	Phone #: (608)269-2778
Mailing Address: R 2 BOX 60	
City: SPARTA	State: WI — Zip Code: 54656
County: Monroe	Co. Permit #: — Notification #: — Completed: 05-04-1992
Well Constructor (Business Name): MAURER, GENE H	Lic. #: 296 — Facility ID # (Public Wells):
Address: RT 4 BOX 272 BLACK RIVER FALLS WI 54615-9804	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.7

1. Well Location

Town of SPARTA

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NE SE or Govt Lot #: — Section: 26 — Township: 18 N — Range: 4 W

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?

OLD SAND POINT WAS PLUGGE

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	95

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K		I		CAVING BLACK DIRT	Surface	2
	Q	C		CAVING BROWN CLAY	2	8
T		S		CAVING BROWN SAND	8	31
G		S		CAVING GRAY SAND	31	76
I		N		WHITE SAND ROCK	76	95

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL 1897 WELD ASTM-A53 SAWHILL TUBULARU.S.A.	Surface	77
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

17 ft. below ground surface

10. Pump Test

Pumping level 23 ft. below surface

Pumping at 10 GP for 3 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
GM		05-13-1992
Drill Rig Operator	Lic or Reg #	Date Signed
MM		05-13-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		61
Building Overhang		5

Type	Qualifier	Distance
Sewer - Building Sanitary		32
Septic or Holding, or POWTS Tank		43

Comment:

Created On: 06-03-1992 Updated On: 06-03-1992 Review Status: