Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EQ355

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: AMIL DAHL	Phone #: (414)725-7505
Mailing Address: 315 6TH ST	
City: MENASHA	State: WI — Zip Code: 54952
County: Portage	Co. Permit #: — Notification #: — Completed: 05-04-1992
Well Constructor (Business Name): SULLIVAN, LYLE C	Lic. #: 120 — Facility ID # (Public Wells):
Address: RT 2 BOX 235 FREDERIC WI 54837-9593	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity:

1. Well Location

Town of LANARL

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NW SE or Govt Lot # — Section: 30 — Township: 22 N — Range: 10 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Driven Point

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
1.25	Surface	31

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 1.25in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	SAND	Surface	31

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
1.25	ASTM A53 USS STEEL 2.30# PER FT THREADED @ COUPLED1.25 OD .140 WALL TYPE TOTAL WEIGHT 71.30	Surface	31
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	DRIVE POINT		31

7. Grout or Other Sealing Material

Method

9. Static Water Level

17 ft. below ground surface

10. Pump Test

Pumping level 17 ft. below surface

Pumping at 6 GP for 2 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
JF		05-06-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JF		05-06-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 06-03-1992 Updated On: 06-03-1992 Review Status: