Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EQ360

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GERALD TREICHEL	Phone #: (715)325-5583
Mailing Address: 1042 E QUEENSWAY	
City: NEKOOSA	State: WI — Zip Code: 54457
County: Adams	Co. Permit #: — Notification #: — Completed: 06-02-1992
Well Constructor (Business Name): FARAGO, JOE	Lic. #: 284 — Facility ID # (Public Wells):
Address: 606 W POPLAR ST, PLAINFIELD WI 54966-9673	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.3

1. Well Location

Town of ROME				Fire # (if avail.): 01042
Street Address or Road Name and Number: 1042 E QUEENSWAY				
Subdivision Name			Lot #	Block #
Latitude / Longitude in Decimal Degree (DD): 44.2005 °N -89.7873 °W				Method Code: GCD013
SW SE or Govt Lot #	Section: 16	Township: 20 N	Range: 6 E	

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	71

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 4in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
I	TOP SOIL	Surface	3
S	SAND	3	40
C	CLAY	40	55
S	SAND	55	71

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	ASTM A53 USS STEEL 11:00# PER FT. THREADED @COUPLED 4 1/2 OD 2.37 WALL TYPE E TESTED 220 PSITOTAL WT 781#	Surface	69
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4		69	71

7. Grout or Other Sealing Material
Method

9. Static Water Level
19 ft. below ground surface

10. Pump Test
Pumping level 29 ft. below surface
Pumping at 13 GP for 3 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
JF		06-04-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JF		06-04-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55

Type	Qualifier	Distance
Building Overhang		7
Septic or Holding, or POWTS Tank		40

Comment:

Created On: 06-24-1992 Updated On: 05-04-2020 Review Status: