

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EQ360		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner GERALD TREICHEL Phone # (715)325-5583						1. Well Location				Fire # (if avail.) 01042			
Mailing Address 1042 E QUEENSWAY						Town of ROME							
City NEKOOSA State WI Zip Code 54457						Street Address or Road Name and Number 1042 E QUEENSWAY							
County Adams		Co. Permit #		Notification #		Completed 06-02-1992		Subdivision Name			Lot #	Block #	
Well Constructor (Business Name) FARAGO, JOE				Lic. # 284	Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.2005 °N -89.7873 °W			Method Code GCD013			
Address 606 W POPLAR ST PLAINFIELD WI 54966-9673				Well Plan Approval #		SW SE	Section 16	Township 20 N	Range 6 E				
Hicap Permanent Well #				Common Well #		Specific Capacity 1.3		2. Well Type New Well					
3. Well serves 1 # of				Hicap Well ? No		of previous unique well # constructed in							
Private, potable				Hicap Property ? No		Reason for replaced or reconstructed well ?							
Heat Exchange ___ # of drillholes				Hicap Potable ?		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole Lower Open Bedrock										
4	Surface	71	Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 4in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)										
6. Casing, Liner, Screen													
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)	To (ft.)	8. Geology						
4	ASTM A53 USS STEEL 11:00# PER FT. THREADED @COUPLED 4 1/2 OD 2.37 WALL TYPE E TESTED 220 PSITOTAL WT 781#				Surface	69	Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)			
4	Screen type, material & slot size				From (ft.)	To (ft.)	I	TOP SOIL	Surface	3			
4	69				71	S	SAND	3	40	C	CLAY	40	55
4	69				71	S	SAND	55	71	11. Well Is	18 in. above grade		
7. Grout or Other Sealing Material													
Method													
9. Static Water Level													
19 ft. below ground surface													
10. Pump Test													
Pumping level 29 ft. below surface													
Pumping at 13 GP for 3 Hrs.													
Pumping Method ?													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller								Lic #	Date Signed				
JF								06-04-1992	Drill Rig Operator				
JF								Lic or Reg #	Date Signed				
06-04-1992								06-04-1992	06-04-1992				

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Building Overhang		7
			Septic or Holding, or POWTS Tank		40

Comment:

Created On: 06-24-1992

Updated On: 05-04-2020

Review Status: