

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EQ361		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner KEN SULLIVAN						Phone # (608)274-0509		1. Well Location				Fire # (if avail.)									
Mailing Address 4125 NAKOMA RD						Town of COLOMA						N152									
City MADISON						State WI		Zip Code 53711				Street Address or Road Name and Number									
County Waushara		Co. Permit #		Notification #		Completed 06-10-1992		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) FARAGO, JOE				Lic. # 284		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.98607 °N -89.55786 °W				Method Code GPS008							
Address 606 W POPLAR ST PLAINFIELD WI 54966-9673				Well Plan Approval #				NE SE		Section 33		Township 18 N		Range 8 E							
				Approval Date (mm-dd-yyyy)				or Govt Lot #													
Hicap Permanent Well #		Common Well #		Specific Capacity 15		2. Well Type Replacement															
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		of previous unique well # constructed in Reason for replaced or reconstructed well ? NOT ENOUGH WATER													
						Hicap Property ? No															
4. Potential Contamination Sources - ON REVERSE SIDE						Hicap Potable ?		Construction Type Drilled													
5. Drillhole Dimensions and Construction Method												8. Geology									
Dia. (in.) 6		From (ft.) Surface		To (ft.) 120		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								S		SAND		Surface		31							
								S G		SAND GRAVEL		31		66							
						N		S		FINE SAND		66		78							
						N		S C		FINE SAND @ CLAY CHIPS		78		82							
						N		S		FINE SAND		82		105							
						M		S		MED SAND		105		120							
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is											
Dia. (in.) 6		Material, Weight, Specification ASTM A1 USS STEEL A53 19.97# PER FT WELDED 6.625"OD X 280 WALL TESTED 2800 PSI				From (ft.) Surface		To (ft.) 116		41 ft. below ground surface				28 in. above grade							
Dia. (in.) 6		Screen type, material & slot size #15 JOHNSON				From (ft.) 116		To (ft.) 120		10. Pump Test				Developed ? Yes							
7. Grout or Other Sealing Material Method						Pumping level 42 ft. below surface Pumping at 15 GP for 1.5 Hrs.				Disinfected ? Yes											
										Capped ? Yes											
Kind of Sealing Material POWDER BENTONITE ALONG CASING						From (ft.) Surface		To (ft.) 0		# Sacks Cement				12. Notified Owner of need to fill & seal ?							
Filled & Sealed Well(s) as needed? Yes						13. Constructor / Supervisory Driller				Lic #		Date Signed									
						JF						06-11-1992									
						Drill Rig Operator				Lic or Reg #		Date Signed									
						TF						06-10-1992									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Building Overhang		9
			Septic or Holding, or POWTS Tank		28

Comment:

Created On: 06-24-1992

Updated On: 08-19-2022

Review Status: